

SUPPLEMENTAL BID BULLETIN NO. 2016-INFR003
 Construction of Twenty-Three Storey with Roof Deck Office Building
 for the Philippine Statistics Authority

In response to the written clarifications of prospective bidders, this Bid Bulletin is issued to clarify matters relative to the Bidding. This shall form an integral part of the Bid Documents.

1. Written Clarification of C.E. Padilla Construction Incorporated

QUERY 1 on Revised BOQ issued			ANSWER*
Description	Initial BOQ	Revised BOQ	
1. Item 1.6.2. Wall Painting	19,740.87 sq.m.	197417.00 sq.m.	Use 19,741.00m²
2. Item 1.3.6. Column Concrete Works	653.39 cu.m.	1,893 cu.m.	Columns under Concreting Works revised as follows: 1.1.6 Columns DESCRIPTION QTY a. 8000 psi 931.00m³ b. 6000 psi 418.00m³ c. 5000 psi 544.00m³
3. Item 1.4.5 Column Rebar works	288,623.74 kgs	612,269.00 kgs	Use 612,269.00 kgs.
4. Item 1.4.6. Beam Rebar Works	848,749.24 kgs	1,467,497.00 kgs	Use 1,467,497.00 kgs.
5. Item 1.5.1. Footing Formworks	1,614.00 sq.m.	6,820.00 sq.m.	Use 6,820.00 m²
6. Item 1.5.5. Column Formworks	3,033.36 sq.m.	9,367.00 sq.m.	Use 9,367.00 m²
7. Item 11.5.8 Stair Formworks	1,699.72 sq.m.	3,550.00 sq.m.	Use 3,550.00 m²
QUERY 2 ON E-FILE OF BOQ			ANSWER*
Please be informed that the Revised BOQ is not programmed to be edited.			Columns 1-4 are password protected and only the following columns shall be edited(password-free): Column 5 -Unit Cost Materials (5) Column 6 -Unit Cost-Labor (6) Column 7 -Total Cost (5 + 6) Column 8 -Total Amount (3 x 7)

***Due to the changes in the quantity, an updated Bill of Quantities (BOQ) is hereby issued in electronic file. Columns 1 to 4 are password protected and only Columns 5 to 8 should be accomplished.**

2. Written Clarification of E.M. Cuerpo-Millennium Erectors Corporation Joint Venture

QUERY	ANSWER
<p>Please provide breakdown of lump sum quantities of the herein-below items in the Concrete Works of the amended Bill of Quantities.</p> <ol style="list-style-type: none"> 1. "1.1.4 Shear wall" 2. "1.1.6 Columns" 3. "1.1.7 Beams" 4. "1.1.8 Suspended Slab" <p>The foregoing items vary in its compressive strength as defined under the General Notes for "Concrete Mixes and Placing" per Structural Sheet 100(S-100) because these items were designated as: 8,000 psi; 6,000psi; and 5,000 psi. Such items necessarily have different unit prices.</p>	<p>Please see attached Updated Bill of Quantities</p>

3. Attachment in relation to Written Clarifications under items 1 and 2

- a. Electronic File of Updated Bill of Quantities such that:

Columns 1-4 are password protected and only the following columns shall be edited(password-free):

- Column 5**-Unit Cost Materials (5)
- Column 6**-Unit Cost-Labor (6)
- Column 7**-Total Cost (5 + 6)
- Column 8**-Total Amount (3 x 7)

4. Reiteration of Contents of Supplemental Bid Bulletin 002 dated 10 December 2016

FROM	TO
Deadline for Bid Submission- 13 December 2016 at 1:00 PM	Deadline for Bid Submission- 19 December 2016 at 1:00 PM
Opening of Bids- 13 December 2016 at 1:30 PM	Opening of Bids- 19 December 2016 at 1:30 PM

Prospective Bidders may still purchase the bidding documents until **12:00 Noon of 19 December 2016.**

5. On Duly Notarized Omnibus Sworn Statement

Attached as Annex “A” of the bid bulletin is the Revised Sample Form of Duly Notarized Omnibus Sworn Statement

6. Reminders

The submission of bids on **19 December 2016 until 1:00 PM** is at:

Philippine Statistics Authority
Bids and Awards Committee
17th Floor, Cyberpod Centris Three,
Eton Centris
Diliman, Quezon City

However, submittals **earlier than 19 December 2016** will be at:

Philippine Statistics Authority
Bids and Awards Committee
11th floor, Cyberpod Centris One
Eton Centris
Diliman, Quezon City