

BIDS AND AWARDS COMMITTEE

BID BULLETIN NO. 1

30 June 2025

PROCUREMENT OF SUPPLY, DELIVERY, AND INSTALLATION OF LED BILLBOARD UNDER PB NO. 2025-13

This Bid Bulletin No. 1 modifies the respective portions of the Bidding Documents issued on 15 June 2025.

The changes to the Bidding Documents, as indicated in the succeeding pages, are being issued in compliance with Section 22.5 of the Revised 2016 Implementing Rules and Regulations of RA 9184. Under this section, the procuring entity is directed to issue an amendment at least seven (7) days before the deadline for submission of the bid.

Except as expressly amended by this Bid Bulletin, all other terms and conditions of the Bidding Documents issued on 15 June 2025 shall remain unchanged and shall remain in full force and effect in accordance with their terms.

For guidance and information of all concerned.

SGD.
MINERVA ELOISA P. ESQUIVIAS
Chairperson
Bids and Awards Committee

**PROCUREMENT OF SUPPLY, DELIVERY, AND INSTALLATION OF LED
BILLBOARD UNDER PB NO. 2025-13**

Bid Bulletin
(As of 30 June 2025)

BB Ref No.	Reference	Amendments/Revisions
BB 1-1	<p><i>Section I. Invitation to Bid</i></p> <p>Bidders should have completed, within the last three (3) years from the date of submission and receipt of bids, a contract similar to the Project.</p>	<p>From:</p> <p>Bidders should have completed, within the last three (3) years from the date of submission and receipt of bids, a contract similar to the Project.</p> <p>To:</p> <p>Bidders should have completed, within the last Five (5) years from the date of submission and receipt of bids, a contract similar to the Project.</p>
BB 1-2	<p><i>Bid Data Sheet</i> <i>ITB Clause 5.3</i></p> <p><i>Similar contracts are the Supply, Delivery and Installation of LED billboard and or Supply and Delivery of Various ICT Hardware.</i></p> <p><i>Bidders should have completed, within five (5) years from the date of submission and receipt of bids, a contract similar to the Project.</i></p>	<p>From:</p> <p><i>Similar contracts are the Supply, Delivery and Installation of LED billboard and or Supply and Delivery of Various ICT Hardware.</i></p> <p>To:</p> <p><i>Similar contracts are the Supply, Delivery and Installation of LED billboard OR Supply and Delivery of Various ICT Hardware.</i></p>
BB 1-3	<p><i>For Section VII, Technical Specifications</i></p> <p><i>Digital Signage Player / LED Display Controller:</i></p>	<p>To include these specifications:</p> <p>2 units of LED display controller with an ultra-large loading capacity and an All-in-One Video Controller (Sender + Processor)</p> <p>VIDEO INPUTS INTERFACES (2 units)</p> <ul style="list-style-type: none"> • 1x DP 1.2 • 2. 1x HDMI 2.0 • 2x DL-DVI <p>OUTPUT INTERFACES (2 units)</p> <ul style="list-style-type: none"> • Gigabit Ethernet Ports • At least 16 x Gigabit Ethernet ports

		<p>Maximum capacity of a single port: For 8-bit input sources: 650,000 pixels For 10-bit/12-bit input sources: 320,000 pixels</p> <ul style="list-style-type: none">• 4x 10G Optical Ports• Max Load Capacity Up to 10.4 million pixels (e.g., 7680x1080 or 3840x2160) <p>CONFIGURATION AND CONTROL (2 units)</p> <ul style="list-style-type: none">• Ethernet Via Control Computer• USB In-Out• Up to 10 units can be cascaded• Includes control software• Remote Management (via LAN, USB, Wi-Fi, or cloud portal)• Auto Backup Redundant input/output and power options• Power : AC 100 V~240 V-50/60 Hz <p>Video Input Management Component (2 units)</p> <ul style="list-style-type: none">• Matrix Switcher with Scaler - Routes any of 4 HDMI sources to any of 4 HDMI displays• Local HDMI output – enables previewing of up to 4 video sources in a multi-view window• Multiple system configuration methods including front panel pushbuttons / RS-232• Ethernet (Telnet / Web GUI) connection, Video Matrix Control app, and Control System <p>HDMI Optical Extender (8 units)</p> <ul style="list-style-type: none">• Extends HDMI video, audio, IR, RS-232 control, and Ethernet signals over a duplex fiber optic cable across up to 10 km <p>HDMI HDBaseT Extender (8 units)</p> <ul style="list-style-type: none">• Supports HDBaseT Long Reach Mode – up to 150 m via a single Cat 5e/6 cable at resolutions up to 1080p
--	--	---

- Supports resolutions of up to 4K and 1080p

**PROCUREMENT OF SUPPLY, DELIVERY, AND INSTALLATION OF LED
BILLBOARD UNDER PB NO. 2025-13**

Question and Answer
(As of 30 June 2025)

Q&A Item No.	BIDDER/S	QUERIES / CLARIFICATION	RESPONSE OF THE BAC-TWG
Q&A 1-1	AVLS ALL VISUAL & LIGHTS SYSTEMS CORPORATION	<p>May we respectfully request for the additional certification requirements as discussed during the pre-bid conference for the assurance that the supplier is a legit and complies with the highest and safety standards</p> <ol style="list-style-type: none"> 1. AVIXA Certification 2. Certified Technology Specialist – General 3. Certified Technology Specialist – Design 4. PCAB license 	<p>Based on the scope of work and the technical specifications, the installation activities involved in the supply, delivery and installation of the LED Billboard are considered incidental to the procurement of goods. The civil or structural components are minor in nature, not constituting a separate infrastructure undertaking, and do not involve complex construction activities.</p> <p>As such, the requirement for a valid PCAB license shall not be imposed for this procurement.</p> <p>Similarly, additional certifications such as AVIXA membership, CTS credentials, while recognized in the industry, are not mandatory and shall not be required nor form part of the eligibility or technical requirements under this procurement.</p>
Q&A 1-2	REMAX INTERNATIONA L INC.	<p>May I ask how many copies of Technical and Financial documents to be submitted during Bid Opening for this project?</p>	<p>Prospective Bidders need only to submit One (1) Original Copy of Technical Component and Financial Component Envelope.</p>

			Also, the PSA requests an additional electronic copy stored in a Flash Drive. However, failure of the Bidders to comply with the said request shall not be a ground for disqualification.
Q&A 1-3	ALJON INTERNATIONAL CORPORATION	<p><i>For Section VII, Technical Specifications</i></p> <p><i>Under General Services</i></p> <p>Does the PSA require the Audio-Visual Technicians/Installers of the company to be a Certified Technology Specialist and Certification Technology Specialist – Designers?</p>	Refer to Q&A 1-1
Q&A 1-4	ALJON INTERNATIONAL CORPORATION	<p><i>For Section VII, Technical Specifications</i></p> <p><i>Under General Services</i></p> <p><i>Supplier must have been operating in the Philippines for over 5 years with experience on delivering and installing LED billboard solutions locally.</i></p> <p>May we respectfully ask if the PSA will require the prospective bidders to submit/provide a Certificate from an International Standard Association (e.g. ANSI, ISO, AVIXA, UL, CE, NFPA 1970) as proof that the company meets all the standards for Audio Visual Technology and Safety Requirements.</p>	Refer to Q&A 1-1
Q&A 1-5	ALJON INTERNATIONAL CORPORATION	May we request that the prospective bidder must have a PCAB License to eliminate the concerns on the structural integrity and other concerns needed?	Since the procurement is listed as “Goods” and not Infra, PCAB license will not be required from the bidder. However, technical drawings and documents should be signed and sealed by a

			licensed professional of its respective trade.
Q&A 1-6	REMAX INTERNATIONAL INC.	<p><i>For Section VII, Technical Specifications</i></p> <p><i>UPS: at least 10 KVA UPS per Unit 3 Years Warranty on Parts (UPS) & 2 Years on Battery or higher with on-site support.</i></p> <p>May we request additional requirements for UPS?</p> <p>UPS: at least 10 KVA UPS per Unit. 3 Years Warranty on Parts (UPS) & 2 Years on Battery or higher with Nationwide on-site support</p> <p>Manufacturer's Certification as Platinum Service Partner of the brand Offer (to ensure support on its nationwide deployment of PSA Equipment.</p>	For the power supply of the PSA HQ building, the 3-phase system is 400V, and the single-phase system is 230V (line to neutral).
Q&A 1-7	REMAX INTERNATIONAL INC.	<p><i>For the Bill of Quantities</i></p> <p>Requesting to Clarify if need to fill-up accomplished this BOQ Form?</p> <p>For clarify if need to include the price to BOQ or put Comply only?</p> <p>Where is the location of BOM attached - 1st envelope for Eligibility and Technical Documents or 2nd Envelope Financial Documents?</p>	<p>Yes, prospective bidders should also accomplish the Bill of Quantities (BOQ) Form</p> <p>Prospective bidders must include the amount in the BOQ</p> <p>The BOQ Form should be attached to the envelope for the Financial Documents.</p>
Q&A 1-8	ADVENUE MEDIA CORPORATION	May I request a copy of the floor plan or base for the property located at Philippine Statistics Authority (PSA). This request is being made for the purpose of Procurement of Supply, Delivery, and Installation LED Billboard.	A PDF copy of the ground floor plan of PSA HQ reflecting the proposed location of the LED billboard will be provided by the BCOM-TWG thru the BAC Sec.

Q&A 1-8	JUMP SOLUTIONS INC.	<p><i>For Section VII, Technical Specifications</i></p> <p><i>UPS:</i> <i>at least 10 KVA UPS per Unit</i> <i>3 Years Warranty on Parts (UPS) & 2 Years on Battery or higher with on-site support</i></p> <p>May we confirm if the UPS is 3-phase 400V?</p>	<p>The voltage system of the PSAHQ building for 3-phase is 400V. We do not have 3-phase, 230V, but we have 230V (line to neutral) for single phase. So, 400V for 3-phase UPS and 230V for single-phase UPS.</p>
---------	---------------------	---	---