

Republic of the Philippines  
Philippine Statistics Authority

---

Reference No. 16BAC00-07

30 May 2016

SUBJECT: BID BULLETIN NO. 1


Dear Prospective Bidder:

This serves as the official transmittal of Bid Bulletin No. 1 for the Procurement for the Supply, Delivery and Installation of Air Conditioning Units and Premium Generator Sets. This bulletin is being issued to amend the Bidding Documents and clarify queries from prospective bidders.

Please be informed that the contents of the Bidding Documents that have not been modified shall remain in full force and effect.

The bulletin shall be posted on both the PHILGEPS and PSA websites.

Truly yours,

  
**JOSIE B. PEREZ**  
BAC Chairperson

  
JPC/alv

Bid Bulletin Ref. No.	Specific Page/Section in the Bidding Docs.	Query/Issue	BAC Response/Clarification
BB1-1	Page 1, No. 1 Section I Invitation to Bid		<p>A. Reduce quantity from 200 ACU to 180 units, ABC = P6,300,000.00</p> <p>B. Change amount of ABC of Split-type aircon from P2,240,000 to P2,940,000.00</p>
BB1-2	Page 9, No. 1 Section I Invitation to Bid	Do you require the prospective bidders to have PCAB license?	No. Please disregard this requirement. This requirement is for construction project only.
BB1-3	Page10, No. 9 Section I Invitation to Bid		Please take note that the Bid Opening shall be held on June 7, 2016 at 2:30 PM at the PSA Conference Room, 17/F CyberpodCentris Three, EDSA cor. Quezon Ave., Diliman, Quezon City.
BB1-4	Page 47, 21 Section III Bid Data Sheet		<p>For bids submitted before June 7, 2016, the address for Submission of Bids is:</p> <p>Bids and Awards Committee Attn: Mr. Joseph P. Cajita 11/F CyberpodCentris One Diliman, Quezon City</p> <p>All bids submitted on June 7, 2016 shall be received in the Conference Room, 17/F CyberpodCentris Three Diliman, Quezon City</p>
BB1-5	Page 46, 18.1 Section III Bid Data Sheet	Aside from the Bid Securing Declaration, do we have to submit another form of bid security?	You may submit either cash or Cashier's/ Manager's Check <b>OR</b> Bid Securing Declaration.
BB1-6	Page 76 Section V Special Conditions of the Contract	Under the Supply, Delivery, Installation and Testing Schedule, it is stated that the supply and delivery and installation period shall be within thirty (30) calendar days upon the issuance of the Notice to Proceed, can we ask for extension?	For all lots, we will extend the supply, delivery and installation period within forty five (45) calendar days upon receipt of Notice to Proceed.

BB1-7	Page 76 Section V Special Conditions of the Contract	For the documentation, we cannot give you the actual manuals during the Post Qualification process.	Brochures or photocopies of user's manuals are acceptable.
BB1-8	Page 77, 1.29 Section V Special Conditions of Contract	We conduct preventive maintenance once only. If you require quarterly preventive maintenance, it will incur additional costs on your part.	Once a year preventive maintenance is acceptable.
BB1-9	Page 82 Section VI Schedule of Requirements		Date of Delivery & Installation  Upon receipt of NTP. NTP is reckoning date of delivery.
BB1-10	Page 85 Section VII Technical Specifications	Must the filtration system be 8-in-1?	Preferably with 8-in-1 filtration system but you can offer other types, as long as it has a filtration system.
BB1-11	Page 86 Section VII Technical Specifications	The refrigerant for the inverter type is R-410A.	Technical Specifications:  Unit Model: Inverter type (using R-410A)
BB1-12	Page 87 Section VII Technical Specifications	Should the Safety Controls have "High and Low Pressure Controls"? What if the manufacturer's standard has only low pressure control?	Preferably high and low pressure control.
BB1-13	Page 87 Section VII Technical Specifications	For the Generator Set, can we offer a unit with a Standby of more than 80 kva? The Rating/Prime and the Standby cannot be the same.	Yes, 80Kva is the minimum requirement.
BB1-14	Page 87 Section VII Technical Specifications	Will you specify the country of origin of the Generator Set?	No preference on the country of origin but we would like to prevent low quality generator sets
BB1-15	Page 88 Section VII Technical Specifications	The Generator Set will need a manual transfer switch.	MTS is acceptable.