



REQUEST FOR QUOTATION

The **Philippine Statistics Authority (PSA)** through the Bids and Awards Committee (BAC), intends to procure **Procurement for Supply of Labor, Materials and Technical Expertise in replacement and installation of brand new compressor of one (1) 3.0 TR capacity Koppel Ceiling Mounted Type Airconditioned-Unit at CVEA Building**

which shall be undertaken in accordance with Section 53.9 (Small Value Procurement) of the 2016 Revised Implementing Rules and Regulations of Republic Act No. 9184, with an Approved Budget of the Contract (ABC) in the amount of **45,000.00** Forty Five Thousand Pesos

Please quote your **best offer** for the **item/s described herein**, subject to the Terms and Conditions provided below. Submit your quotation duly signed by you or your duly authorized representative **not later than** JUL 26 2024 at 11:00am through email at bac-secretariat@psa.gov.ph.

For any clarification, you may contact us at telephone no. **(02) 8374-8263** or email address at gsdprocurement.psa@gmail.com

for duty
MINERVA ELOISA P. ESQUIVIAS
 Chairperson, Bids and Awards Committee

TERMS AND CONDITIONS

- 1 Bidders shall provide correct and accurate information required in this form.
- 2 Price quotation/s must be valid for a period of **thirty (30) calendar days** from the date of submission.
- 3 Price quotation/s, to be denominated in Philippine peso, shall include all taxes, duties and/or levies payable.
- 4 Quotations exceeding the ABC shall be rejected.
- 5 Award of contract shall be made to the lowest calculated and responsive bid (LCRB).
- 6 Any interlineations, erasures or overwriting shall be valid only if they are signed or initialed by you or your duly authorized representative.
- 7 In case of two or more bidders are determined to have submitted the LCRB, the PSA shall adopt and employ "draw lots" as the tie-breaking method to finally determine the single winning bidder in accordance with GPPB Circular 06-2005.
- 8 The item/s shall be delivered according to the requirements specified in the Purchase Request (PR).
- 9 The PSA shall have the right to inspect and/or test the goods to confirm their conformity to the Technical Specifications.
- 10 Payment shall be made after delivery and upon submission of the required supporting documents, i.e. Order Slip and/or Billing Statement, by the supplier. Our Government Servicing Bank, **Land Bank of the Philippines**, shall credit the amount due to the identified bank of the supplier **not earlier than twenty four (24) hours, but not later than forty eight (48) hours**, upon receipt of our advice. Please note that the corresponding bank **transfer fee** if any shall be chargeable to the account of the supplier.
- 11 Liquidated damages equivalent to one tenth (1/10) of one percent (1%) of the value of the goods not delivered within the prescribed period shall be imposed per day of delay. The PSA shall rescind the contract once the cumulative amount of liquidated damages reaches ten percent (10%) of the amount of the contract without prejudice to other courses of action and remedies open to it.

Documents to be submitted	Deadline	Remarks
Copy of the 2024 Mayor's/Business Permit and valid PhilGEPS Registration	not later than <u>JUL 26 2024</u> at <u>11:00am</u>	together with the quotation



REQUEST FOR QUOTATION

PR No. 24-07-0781

After having carefully read and accepted the Terms and Conditions, I/We submit our quotation/s for the item/s as follows:

Item(s) and Specification(s), minimum	Unit	Quantity	Unit Price	Total Amount (VAT Inclusive)	Compliance with Technical Specifications (pls. check)	
					Yes	No
Procurement for Supply of Labor, Materials and Technical Expertise in replacement and installation of brand new compressor of one (1) 3.0 TR capacity Koppel Ceiling Mounted Type Airconditioned-Unit at CVEA Building	lot	1				
Including the following Scope of Works: - Dismantle defective 3 TR compressor and suction and discharge copper pipes loop - Flush the system using R-141b and dry nitrogen pressure to remove acid refrigerant oil inside the evaporator, condenser coil and field piping - General cleaning of indoor and outdoor coil using pressure washer and soft solution. Clean air filters, front panel of indoor unit and panels of outdoor unit - Install the new compressor, brazing of suction and discharge loop and re-connect suction, liquid line field piping and re-connect all electrical interconnection - Leak testing using dry nitrogen pressure, 150 psig and use leak detector to insure no leakage - Triple evacuation of system using vacuum pump to insure non condensable air inside the system - Recharge refrigerant-22, test run, observation and record all necessary data of operation						
Model : KCM-36R1/KPC-361HO Serial No. LD293095/LD323308 Location: SOID Server Room, 2nd Floor CVEA Building						
Total amount in words:						

Printed name of the authorized representative: _____ Signature: _____

Name of Company: _____ Position: _____

Address: _____ Email address: _____

Fax No.: _____ Tel. No.: _____ Mobile No.: _____

Date: _____