

Bid Bulletin Ref. No.	Specific Page/Section in the Bidding Docs.	Query/Issue	BAC Response/Clarification
BB1-1	Page 83, Section VI Schedule of Requirements	How long is the installation period? Can we hasten the installation period?	The supply, delivery and installation of carpet tiles shall be completed within thirty (30) calendar days upon receipt of the Notice to Proceed (NTP). The issuance of the NTP is on 07 November 2017. Yes, as long as the quality of work will not suffer.
BB1-2	Page 87, Section VII Technical Specifications	From and to what time can we work during weekdays and weekend?	On weekdays, you can work from 7:00 PM to 4:00 AM, and on weekends, you can work from 8:00 AM to 5:00 PM.
BB1-3	Page 87, Section VII Technical Specifications	Is the carpet tile made of yarn? Do you require us to issue a certification that the tile has anti-static or fire retardancy components? Please provide detailed specifications or properties of the carpet tile.	Yes. Nylon, Anti-Static, Fire Retardant, Loop Pile Carpet with 4 or 7 mm thickness.
BB1-4	Page 87, Section VII Technical Specifications	Since the dimension of most of the carpet tiles today is 45 cm x 45 cm, can we use this instead of the 50 cm x 50 cm?	No, since the dimension of the existing tiles is 50 cm x 50 cm, we require you to use this dimension for easy installation.
BB1-5	Page 87, Section VII Technical Specifications	Can we submit an alternative design to the sample presented for your approval?	Yes, you can submit similar design as long as the color is gray or dark gray and 50x50cm subject for the approval of the TWG.
BB1-6	Page 51, ITB Clause No. 12.1(a)(ii) Section III Bid Data Sheet	For the SLCC, what is considered as similar contracts?	Similar contract refers to installation of carpet tiles.
BB1-7		Will you require us to issue a certificate of site inspection?	Yes
BB1-8			Removal and Scraping of Old Carpet tiles shall also be done by the winning bidder.

7