



Republic of the Philippines

PHILIPPINE STATISTICS AUTHORITY

BID BULLETIN NO. 1

**CONSTRUCTION OF REINFORCED CONCRETE RETAINING WALL PHASE II
15 OCTOBER 2015**

Bid Bulletin Ref. No.	Specific Page/Section in the Bidding Docs	Query/Issue	BAC Response/ Clarification
BB-01	Page 104- Bill of Quantities	Clarification on the specifications of : Gravel (G-1, CRUSHED) Steel Reinforcement - 16mm - 12mm - 10mm - Angle bar (2x2x 1/4) - Steel matting (2 x 2 x no. 6) - Barbed wire	The specification is now stated as: Gravel (G-1 and 3/4, CRUSHED) Steel Reinforcement - 16mm (GRADE 60) - 12mm (GRADE 60) - 10mm (GRADE 60) - Angle bar (2x2x 1/4) - Steel matting (2 x 2 x no. 6) - Barbed wire