



REPUBLIC OF THE PHILIPPINES
PHILIPPINE STATISTICS AUTHORITY

Reference No. 17BAC-0028

22 September 2017

SUBJECT: BID BULLETIN NO. 1

Dear Prospective Bidder:

This serves as the official transmittal of Bid Bulletin No. 1 for the Procurement for the Procurement of Steel Racks. This bulletin is being issued to amend the Bidding Documents and clarify queries from prospective bidders.

Please be informed that the contents of the Bidding Documents that have not been modified shall remain in full force and effect.

The bulletin shall be posted on both the PHILGEPS and PSA websites.

Truly yours,


JOSIE B. PEREZ
(Deputy National Statistician)
Officer-In-Charge BAC Chairperson

JPC/alv


Bid Bulletin Ref. No.	Specific Page/Section in the Bidding Docs.	Query/Issue	BAC Response/Clarification
BB1-1	Page 86, Section VII Technical Specifications	<p>Regarding the post, is the angle bar slotted?</p> <p>Is the color of the post black?</p>	<p>Yes.</p> <p>No. The material of the post is made of Black Iron (B.I.) Sheet.</p> <p>The color of the steel rack is light gray.</p>
BB1-2	Page 51, ITB Clause No. 12.1(a)(ii) Section III Bid Data Sheet	For the SLCC, would you consider furniture such as filing cabinets or gang chairs made of steel as similar contracts?	Similar contracts are <u>Steel Racks</u>
BB1-3	Page 76, Section V Special Conditions of Contract		<p>The project site is at;</p> <p>JACALA Warehouse Amparo Subdivision Caloocan City</p>
BB1-4	Page 86, Section VII Technical Specifications	Under Assembly, are the corner plates placed on the top and bottom shelves only or on all the shelves?	The corner plates are placed on all the shelves.
BB1-5	Page 87, Section VII Technical Specifications	Regarding the support, are the bottom stiffeners along the width?	The bottom stiffeners are along the width of each layer.
BB1-6	Page 75, Section V Special Conditions of Contract	<p>Are we going to submit a manufacturer's certificate?</p> <p>How long is the warranty period?</p>	<p>Yes. Original and four (4) copies of Manufacturer's and/or Supplier's warranty certificate.</p> <p>The manufacturer will issue the warranty of their product.</p>

Procurement of 250 Steel Racks

Proposed Rack Specifications:

- 9 Adjustable shelves with eight (8) layers
- Shelves – manufactured from heavy duty cold rolled sheets, ga. No: 20, 0.9mm thickness, provided with two (2) bottom stiffeners
- Post – fabricated in black iron (B. I) sheet, ga. No: 14, 2.0mm thickness in slotted angle bar, 1½" x 1½" **with rubber footing on each post.**
- Assembly – two sides with two vertical stoppers flat bar 1/8" thickness x 1" and supported by corner gusset, **14 ga. 2.0 mm steel thickness** installed alternately on shelves. All parts are bolted at ¼" x 1/2" **hexagonal machine bolt**, with 1-1/2" distance to allow for shelves to be adjusted
- Powder coated –hi bake, color – gray
- Dimension: 2360mmH x820mmW x750mmD

